

Summary Report

www.bsria.co.uk

Summary Report 53928/2

Issue No: 1

Date of issue: 10 October 2018

This Summary Report confirms that BSRIA Ltd has tested a sample of the product described below in accordance with the test methods contained within EN 13030 : 2001 and have determined the item met the detailed classification shown on pages 3 to 5. For further details of the test item see Page 2 of this Summary Report.

Manufacturer/Agent	N.V. Renson Projects IZ 2 Vijverdam Maalbeekstraat 6 B-8790 Waregem
Product	L.066V
Test location	BSRIA Old Bracknell West Bracknell Berkshire RG12 7AH
Date of test	18 January to 4 February 2010
Date of issue	9 October 2018
Test engineer	A Freeth
Quality approved	Mark Roper Principal Test Engineer

This Summary Report must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

This summary report supersedes certificate 53928/2. This up-date was carried out under BSRIA contract reference 61223.

TEST INFORMATION

Contract	53928A
Date	18/01/2010
Manufacturer	Renson
Louvre Model	L.066V vertical
Material	Aluminium
Painted	No
Blade Height	1000 mm
Blade Width	998 mm
Blade Depth	80 mm
Frame Depth	85 mm
No.of Blades	15
Blade Pitch	66 mm
Blade Angle	45 Degrees
No.of Banks	1
Guard Type	Insect
Guard Spacing	5
Side Channels	No
Water Drip Tray	Yes
Blade Orientation	Vertical

Front view of louvre


RAINWATER PENETRATION

MANUFACTURER Renson
 MODEL L.066V vertical

Date 18/01/2010
 Contract 53928A

Simulated rainfall 75 mm/hr
 Wind speed 13.0 m/s
 louvre height 1000 mm
 louvre width 998 mm
 louvre area 0.998 m²

VENTILATION RATE		WATER FLOW RATES		Effectiveness	Class
Volume m ³ /s	Velocity m/s	Supply l/h	Penetrated l/h		
0.00	0.00	93.0	0.0	100.0%	A
0.50	0.50	93.0	0.0	100.0%	A
1.00	1.00	93.0	0.0	100.0%	A
1.50	1.50	93.0	0.2	99.7%	A
2.00	2.00	93.0	14.8	80.2%	C
2.50	2.50	93.0	66.4	11.3%	D
3.00	3.00	93.0	68.9	7.9%	D




COEFFICIENT OF ENTRY

MANUFACTURER Renson
 MODEL L.066V vertical

Date 18/01/2010
 Contract 53928A

air temperature 14.9 °C louvre height 1000 mm
 barometer 1026 mbar louvre width 998 mm
 air density 1.236 kg/m³ louvre area 0.998 m²

louvre pd Pascals	louvre face velocity		air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s		
29.5	0.88	0.880	6.895	0.128	
47.9	1.12	1.122	8.787	0.128	
75.8	1.41	1.408	11.053	0.127	
103.7	1.64	1.637	12.928	0.127	
126.0	1.84	1.839	14.251	0.129	
160.2	2.08	2.075	16.069	0.129	
200.1	2.34	2.335	17.959	0.130	
258.7	2.67	2.667	20.420	0.131	
310.8	2.92	2.910	22.382	0.130	
343.2	3.08	3.073	23.519	0.131	
				mean C _e	0.129
				Class	4




COEFFICIENT OF DISCHARGE

MANUFACTURER Renson
 MODEL L.066V vertical

Date 04/02/2010
 Contract 53928A

air temperature	18 °C	louvre height	1000 mm
barometer	999.4 mbar	louvre width	998 mm
air density	1.191 kg/m ³	louvre area	0.998 m ²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _d
	m/s	test m ³ /s	theoretical m ³ /s	
37.4	0.90	0.902	7.909	0.114
71.9	1.26	1.255	10.966	0.114
112.9	1.57	1.568	13.741	0.114
169.4	1.93	1.926	16.832	0.114
238.1	2.30	2.294	19.955	0.115
324.0	2.64	2.639	23.279	0.113
386.6	2.91	2.905	25.428	0.114
406.3	2.99	2.983	26.068	0.114
mean C _d				0.114
Class				4



CLASSIFICATION OF WEATHER LOUVRES

Weather louvres shall be classified by their ability to reject simulated rain.

Penetration Classification

Table 1 shows the different classifications based on the maximum simulated rain penetration per square metre of louvre. The classification is determined in accordance with section 8.2 of EN 13030:2001.

Water penetration rating at a given louvre face velocity is determined by the water penetration while the louvre is subjected to a 13 ms^{-1} simulated wind velocity and a simulated rain fall at the nominal rate.

Table 1 Penetration classification

Class	Effectiveness	Maximum allowed penetration of simulated rain $\text{l.h}^{-1}.\text{m}^{-2}$
A	1,00 TO 0,99	0,75
B	0,989 TO 0,95	3,75
C	0,949 TO 0,80	15,0
D	Below 0,8	Greater than 15,0

These classifications apply to various core velocities.

Discharge and Entry Loss Coefficient

The discharge and entry loss coefficient given in Table 2, shall be determined in accordance with section 8.3 of test standard EN13030:2001.

Table 2 Discharge and Entry loss coefficient classification

Class	Discharge and Entry Loss Coefficient
1	0,4 and above
2	0,3 to 0,399
3	0,2 to 0,299
4	0,199 and below