

Weather Louvre Test

L.050IM1

Carried out for
nv Renson Ventilation sa

Report 61220/3

Compiled by Paul Ainscoe

5 December 2018



This page is intentionally left blank

Weather Louvre Test

L.050IM1

Carried out for: nv Renson Ventilation sa
Maalbeekstraat 6
8790 - Waregem
Belgium

Contract: Report 61220/3

Issued by: BSRIA Limited
Old Bracknell Lane West
Bracknell
Berkshire
RG12 7AH
UK


Telephone: +44 (0)1344 465600

Fax: +44 (0)1344 465626

Email: bsria@bsria.co.uk

Website: www.bsria.co.uk

QUALITY ASSURANCE

Issue	Date	Compiled by:	Approved by:	Signature
Draft	05-Dec-2018	Paul Ainscoe	Mark Roper	
		Test Engineer	Principal Test Engineer	

DISCLAIMER

This Document must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

This Document has been prepared by BSRIA Limited, with reasonable skill, care and diligence in accordance with BSRIA's Quality Assurance and within the scope of our Terms and Conditions of Business.

This Document is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the Document at its own risk.

CONTENTS

1 INTRODUCTION.....5
 1.1 Test item information.....5
2 TEST METHOD7
 2.1 Water penetration.....7
 2.2 Pressure drop7
 2.3 Test equipment used7
3 RESULTS8
 3.1 Rainwater Penetration8
 3.2 Coefficient of Entry.....9
 3.3 Coefficient of Discharge10

FIGURES

Figure 1 Test item 61220A3 (front) 6
Figure 2 Test item 61220A3 (rear)..... 6

APPENDICES

APPENDIX A: MANUFACTURERS DRAWING..... 11

1 INTRODUCTION

This report concerns tests conducted on a louvre to determine the Rainwater Penetration and the Pressure Drop versus Airflow Curves, with the associated Coefficients of Discharge and Entry, using the test methods contained within EN 13030:2001. It should be noted that BS EN 13030:2001 simply provides a method for testing and rating louvre samples, there are no minimum permitted values or recommendations for louvre performance.

The work was commissioned by nv Renson Ventilation sa and was carried out at BSRIA North on 23 to 24 August 2018.

Items received for test

Test Item	BSRIA ID
L.050IM1	61220A3

1.1 TEST ITEM INFORMATION

Contract	61220
Date	20-8-18
Manufacturer	nv Renson Ventilation sa
Louvre Model	L.050IM1
Material	Aluminium
Painted	No
Core Area Height	975 mm
Core Area Width	995 mm
Blade Pack Depth	41 mm
Frame Depth	50 mm
No. of Blades	19
Blade Pitch	50 mm
Blade Angle	45° approx.
No. of Banks	1
Guard Type	None
Guard Spacing	N/A
Side Channels	No
Water Drip Tray	No
Blade Orientation	Horizontal

Note: Weather louvre core area - product of the minimum height H and minimum width W of the front opening in the weather louvre assembly with the louvre blades removed
Blade Pack Depth refers to the distance from front of first bank to rear of last bank.

Figure 1 Test item 61220A3 (front)




Figure 2 Test item 61220A3 (rear)



2 TEST METHOD

A schematic representation of the rig used during testing



The test comprises of two parts:

2.1 WATER PENETRATION

The weather louvre is subjected to fan driven wind at a speed of 13 m/s and water sprayed as rainfall at a rate of 75 l/h. In addition to the simulated wind and rain, air is drawn through the louvre at various set velocities (0, 0.5, 1.0, 1.5, 2.0, 2.5, 3.0 and 3.5 m/s).

Each test is preceded by a suitable 'pre-test' soak which is typically around 30 minutes. Each test is run until the results become stable, and in any case, for a minimum of 30 minutes.

The penetrated water is collected in the collection duct and is measured and recorded against time elapsed.

A range of measurements are taken to give the characteristic curve for the test louvre.

2.2 PRESSURE DROP

For this test, the Aerodynamic Measuring Section (AMS) is separated from the main rig. The louvre is then mounted in the upstream opening of the AMS.

Pressure tappings in the plenum walls of the AMS allow measurement of the static pressure within the plenum during testing. The airflow volume is calculated from the differential pressure at the measuring cones. The plenum has a set of settling screens within to produce even flow through the cones and therefore gives an accurate reading of the total volume.

By adjusting the fan speed, the total airflow through the system varies and therefore changes the pressure on the louvre under test. A range of measurements are taken to give the characteristic curve for the test louvre.

2.3 TEST EQUIPMENT USED

Test equipment	BSRIA ID	Calibration Expiry Date
Water supply measurement	352	19-4-19
Rain measuring system	353	20-4-19
Airflow cones	364	17-1-19
Micromanometer	1600	21-12-18
Micromanometer	1601	21-12-18
Scales (water)	1599	26-6-19
Flow meter	1688	29-5-19

3 RESULTS


3.1 RAINWATER PENETRATION

MANUFACTURER nv Renson Ventilation sa
 MODEL L.050IM1

Date 23/08/2018
 Contract 61220

Simulated rainfall 75 mm/hr
 Wind speed 13.0 m/s
 louvre height 975 mm
 louvre width 995 mm
 louvre area 0.970 m²

VENTILATION RATE		WATER FLOW RATES		Effectiveness	Class
Volume m ³ /s	Velocity m/s	Supply l/h	Penetrated l/h		
0.00	0.00	100.2	6.2	91.5%	C
0.48	0.50	100.2	9.6	86.9%	C
0.97	1.00	100.2	12.2	83.2%	C
1.46	1.50	100.2	15.0	79.3%	D
1.94	2.00	100.2	22.4	69.1%	D
2.43	2.50	100.2	39.6	45.6%	D
2.91	3.00	100.2	48.2	33.7%	D
3.39	3.50	100.2	60.0	17.5%	D




3.2 COEFFICIENT OF ENTRY

MANUFACTURER nv Renson Ventilation sa
 MODEL L.050IM1

Date 24/08/2018
 Contract 61220

air temperature 17.4 °C louvre height 975 mm
 barometer 1005 mbar louvre width 995 mm
 air density 1.201 kg/m³ louvre area 0.970 m²

louvre pd Pascals	louvre face velocity		air flow rate		coefficient C _e
	m/s		test m ³ /s	theoretical m ³ /s	
10.4	1.05		1.016	4.038	0.252
26.6	1.65		1.598	6.458	0.247
44.8	2.12		2.059	8.381	0.246
61.5	2.48		2.402	9.819	0.245
79.9	2.80		2.719	11.192	0.243
93.5	3.05		2.960	12.107	0.245
113.0	3.34		3.242	13.310	0.244
130.0	3.60		3.492	14.276	0.245
148.0	3.80		3.687	15.232	0.242
169.0	4.08		3.961	16.277	0.243
mean C _e					0.245
Class					3



A 'trendline' for the above graph would follow $y = 10.155x^{2.0488}$


3.3 COEFFICIENT OF DISCHARGE

MANUFACTURER nv Renson Ventilation sa
 MODEL L.050IM1

Date 24/08/2018
 Contract 61220

air temperature 17.6 °C louvre height 975 mm
 barometer 1005 mbar louvre width 995 mm
 air density 1.200 kg/m³ louvre area 0.970 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _d
	m/s	test m ³ /s	theoretical m ³ /s	
10.7	0.93	0.904	4.097	0.221
25.4	1.44	1.401	6.313	0.222
41.2	1.85	1.796	8.040	0.223
62.0	2.25	2.188	9.863	0.222
83.8	2.62	2.544	11.466	0.222
106.0	2.92	2.835	12.896	0.220
126.0	3.17	3.077	14.060	0.219
147.0	3.42	3.321	15.187	0.219
172.0	3.73	3.614	16.427	0.220
206.0	4.06	3.938	17.978	0.219
mean C _d				0.221
Class				3



A 'trendline' for the above graph would follow $y = 12.898x^{2.0178}$

APPENDIX A: MANUFACTURERS DRAWING

